



Test Verification of Conformity

Certificate No.: CTW2502000301

Issue Date: Feb.11, 2025

In accordance with the following applicable Directives:

Radio Equipment Directive (RED) 2014/53/EU

The equipment, as described herewith, was tested pursuant to applicable test procedure and complies with the requirements of:

Essential Requirement		Applied Standards	Test Report No.	Result
Art. 3.1a	Health	EN IEC 62311:2020	CHTW25020006	Conform
	Safety	EN 61010-1:2010+A1:2019 EN IEC 61010-2-030: 2021+A11:2021 for use in conjunction with EN 61010-1:2010+A1:2019	CHTE25010067 CHTE25010068	Conform
Art. 3.1b	EMC	ETSI EN 301 489-1 V2.2.3, ETSI EN 301 489-3 V2.3.2, ETSI EN 301 489-17 V3.3.1, EN IEC 61326-1: 2021, EN IEC 61326-2-3: 2021	CHTW25020005 CHTE25010060	Conform
Art. 3.2	Radio	ETSI EN 300 328 V2.2.2, ETSI EN 300 220-1 V3.1.1 ETSI EN 300 220-2 V3.1.1	CHTW25020003 CHTW25020004	Conform

The test results are traceable to the international or national standards.

Applicant: Zhejiang Eastron Electronic Co.,Ltd

Address: No.52,Dongjin Road,Nanhu,Jiaxing,Zhejiang,China

EUT Name: Three phase Energy Meter

Trade Mark: -

Model number: SEM5

Listed Model(s): SEM5-1,SEM5-2,SEM5-3,SEM5-5

Test Laboratory: Shenzhen Huatongwei International Inspection Co., Ltd.

Building 7,Baiwang Idea Factory, No.1051,Songbai Road,Yangguang Community,Xili Subdistrict,
Nanshan District, Shenzhen, Guangdong, China

Tel: 86-755-26715499 E-mail: cs@szhtw.com.cn Website: Http: //www.szhtw.com.cn

Note:

The certification is only valid for the equipment and configuration described, in conjunction with the test data detailed above. The CE mark as shown beside can be used, under the responsibility of the manufacturer, after completion of an EC Directive of Conformity and compliance with all relevant EC Directive.

For and on behalf of
Shenzhen Huatongwei International Inspection Co., Ltd.

Authorized by:

